

**Regulation 113**

**HIGH-PRESSURE SERVICE**

(a) **General**

The System maintains and reserves an absolute right to provide service to any and all portions of its service area under conditions of "High-Pressure Service," wherein pressures at meters or service connections exceed ninety (90) pounds per square inch.

(b) **Property Owner's Responsibility**

In any area of High-Pressure Service, it shall be the responsibility of the property owner of each such served connection, at property owner's expense and risk, to provide, operate and maintain a pressure regulating device of a design, type, standard and installation specified by the System and conforming in all respects to all applicable Standard Drawings adopted by and for the System.

(c) **System Installed Regulators**

In the event service to a connection not already designated a High-Pressure Service is affected as a result of a System improvement program or project such that pressure at the meter or service connection will exceed eighty (80) pounds per square inch, the System shall install or cause to be installed at said service connection, and at System's sole expense, a pressure regulator device. Upon such installation, ownership of the regulator device shall pass to the property owner who shall from that time on be solely responsible for its operation, maintenance, repair and replacement

(d) **New Service Connection**

An applicant for a new service connection designated by the System as a High-Pressure Service shall, as a condition of acceptance by the System of the application agree in writing to provision of a High-Pressure Service and to the applicability of this Regulation to the service being applied for.

\* \* \* \* \*

*Regulation 113: Adopted, July 20, 1983 (Ord. 83-2)*